

ECODESIGN REQUIREMENTS FOR SOLID FUEL BOILERS ACCORDING TO COMMISSION REGULATION (EU) 2015/1189 AND ECOLABEL REQUIREMENTS FOR SOLID FUEL BOILERS ACCORDING TO COMMISSION REGULATION (EU) 2015/1187

BIODOM – BIODOM 27

Stoking mode: Automatic: it is recommended that the boiler be operated with a hot water storage tank of a volume of at least 510 litres (**)

Condensing boiler: no

Solid fuel cogeneration boiler: no

Combination boiler: no

Fuel	Preferred fuel (only one):	Other suitable fuel(s):	η_s [%]:	Seasonal space heating emissions			
				PM	OGC	CO	NO _x
				mg/m ³ at 10%O ₂			
Log wood, moisture content ≤ 25 %	no	no					
Chipped wood, moisture content 15-35 %	no	no					
Chipped wood, moisture content > 35 %	no	no					
Compressed wood in the form of pellets or briquettes	yes	no	82	13	2	74	146
Sawdust, moisture content ≤ 50 %	no	no					
Other woody biomass	no	no					
Non-woody biomass	no	no					
Bituminous coal	no	no					
Brown coal (including briquettes)	no	no					
Coke	no	no					
Anthracite	no	no					
Blended fossil fuel briquettes	no	no					
Other fossil fuel	no	no					
Blended biomass (30-70 %)/fossil fuel briquettes	no	no					
Other blend of biomass and fossil fuel	no	no					

(**) Tank volume = $20 \times P_r$ with P_r indicated in kW

Characteristics when operating with the preferred fuel only:								
Seasonal space heating energy efficiency η_s [%]: 82								
Energy efficiency index EEI: 121				Energy efficiency class: A+				
Item	Symbol	Value	Unit		Item	Symbol	Value	Unit
Useful heat output				Useful efficiency (GCV as received)				
At rated heat output	P_n	25,5	kW		At rated heat output	η_n	93,4	%
At [30 %/50 %] of rated heat output, if applicable	P_p	6,9	kW		At [30 %/50 %] of rated heat output, if applicable	η_p	92,2	%
For solid fuel cogeneration boilers: Electrical efficiency				Auxiliary electricity consumption				
At rated heat output	$\eta_{el,n}$	N.A.	%		At rated heat output	el_{max}	0,054	kW
					At [30 %/50 %] of rated heat output, if applicable	el_{min}	0,024	kW
					Of incorporated secondary emission abatement equipment, if applicable		N.A.	kW
					In standby mode	P_{SB}	0,003	kW
Contact details	Name and address of the manufacturer or its authorized representative.							
Tel. +386(0)56801456 www.biodom27.si info@biodom27.si	Manufacturer: BIODOM 27 D.O.O. Oic Hrpelje 4a 6240 KOZINA SLOVENJA							

Issue date: November 28, 2024

Head of Test Laboratory
Dr.ssa Claudia Marcuzzi

Firmato
digitalmente da
MARCUIZZI
CLAUDIA
Data: 2024.11.28
08:45:35 +01'00'